



Dos Rios WRC Digester Gas Utilities Transfer Project

October 23, 2009 LNV Pre-Bid Meeting Notes

Ms. Alissa R. Locket, P.E. of SAWS Production and Treatment Engineering conducted the meeting and reviewed the prepared agenda which was distributed before the meeting started. The following items were also mentioned:

- The existing propane tank will have to be emptied by the contractor before it is relocated. The contractor is to coordinate with Dos Rios WRC staff to reduce the stored volume before relocation.
- SAWS staff requested confirmation that properly qualified personnel would be relocating the propane system and installing the temporary propane system. LNV indicated that there were agencies/entities other than the TNRCC were involved with propane system compliance. After the meeting they were informed by LNV of extensive notes in this regard on sheet C 10 of 13 and compliance with State of Texas Railroad Commission regulations and licensing.
- SAWS asked LNV whether or not the proposed 316 L Schedule 10 stainless steel gas line was strong enough to hold a full vacuum. This was confirmed by LNV as their staff had researched this topic with suppliers.
- It was stressed by SAWS staff to all potential bidders that all questions asked during this pre-bid meeting should be submitted to Diana Dwyer of SAWS contracting so that they can be included in future addenda.
- SAWS staff commented on the propane vaporizers as to whether or not they will be relocated or eliminated. They were informed that they will be relocated.
- LNV and SAWS both indicated that coordination with Dos Rios WRC staff is a high priority. The contractor will be required to submit a construction schedule. Since conditions and situations in the field change during construction, Dos Rios WRC staff must be informed of what plant facilities are being impacted, as facilities will be in service throughout construction.
- Inconsistency in the contract documents regarding the pre-bid meeting being mandatory or non-mandatory will be clarified as non-mandatory in a future addendum.
- LNV accompanied the representative from Austin Engineering to the Dos Rios WRC for an optional project site visit.


Julian P. Bielawski, P.E.


Date

