



Notes:

1. Customer's yard piping consists of water supply piping and appurtenances between the customer's side of the Cut-Off Valve and the nearest point of the largest existing connection within the customer's property.
2. Yard piping alignment shall be established in the field by Inspector.
3. Existing customer's yard piping to the abandoned main shall be cut and capped inside the customer's property.
4. Yard piping pay item:
 - A. Short Yard Piping: When yard piping is less than 1/2 the depth of the lot.
 - B. Long Yard Piping: When yard piping is more than 1/2 the depth of the lot.
5. Install SCH 80 PVC Coupling at the location where dissimilar pipe material is encountered.

PROPERTY OF
SAN ANTONIO WATER SYSTEM
 SAN ANTONIO, TEXAS

**RELOCATE SERVICE
 AND RECONNECTION OF
 CUSTOMER'S YARD PIPING
 (RESIDENTIAL)**

APPROVED
 AUGUST 1998

REVISED

DD-822-01

SHEET
 1 OF 1