



Note:

All concrete used for thrust blocking shall have a minimum concrete strength of 3500 psi

PROPERTY OF SAN ANTONIO WATER SYSTEM SAN ANTONIO, TEXAS	TYPICAL THRUST BLOCKS (SEWER ONLY)	APPROVED	REVISED
		AUGUST 1998	SEPTEMBER 2000
		DD-839-03	
			SHEET <u>1</u> OF <u>1</u>