



SANITARY SEWER STRUCTURE
6' & 8' STRUCTURE TYPE "B" & "C"

Notes:

The channel depth shall be at least equal to the largest pipe diameter.
 Structures shall be designed and installed on all mains greater than 24" in diameter.

PROPERTY OF
SAN ANTONIO WATER SYSTEM
 SAN ANTONIO, TEXAS

**TYPICAL SANITARY
 SEWER STRUCTURE**

APPROVED
 AUGUST 1998

REVISED

DD-850-01

SHEET
 1 OF 1