



MONOLITHIC MANHOLE

General Notes:

- 1) Material for sanitary sewer pipe must be the same from manhole to manhole. Changes in type of pipe may be made only at manholes, or special structures, except as approved by the SAWS project Engineer.
- 2) Adaptors and Concrete Collars shall be used as directed by the Engineer and as approved by the SAWS project Engineer.
- 3) Watertight manhole rings and covers shall be Trans-Tex A77 "O" Ring or approved equal.

PROPERTY OF SAN ANTONIO WATER SYSTEM SAN ANTONIO, TEXAS	STANDARD MONOLITHIC MANHOLE	APPROVED	REVISED
		AUGUST 1998	
		DD-852-01	SHEET <u>2</u> OF <u>2</u>