



NOTE:  
 20" AND SMALLER, USE GATE VALVE, FLG.  
 24" AND LARGER, USE BUTTERFLY VALVE, FLG.

NOTE:  
 FITTINGS AND PIPE SIZE TO BE DETERMINED BY ENGINEER.

SIDE VIEW  
 SECTION AA

PROPERTY OF SAN ANTONIO WATER SYSTEM SAN ANTONIO, TEXAS	ALTITUDE VALVE ASSEMBLY		APPROVED 7-14-00	REVISED
			DD-901-04	SHEET 1 OF 3