



FRONT VIEW

SIDE VIEW

NOTE:  
 CONCRETE SLAB TO BE 3000 P.S.I. STRENGTH @ 28 DAYS.  
 WELL PUMP AND CATHODIC RECTIFIER PANELS TO BE INSTALLED 10' MIN. FROM TANK.

PROPERTY OF SAN ANTONIO WATER SYSTEM SAN ANTONIO, TEXAS	LEVEL PRESSURE TRANSMITTER		APPROVED	REVISED
			7-14-00	
			DD-901-08	SHEET 1 OF 3