

15-01

SAN ANTONIO WATER SYSTEM SAN ANTONIO, TEXAS

SPECIFICATIONS FOR COPPER TUBING REVISED FEBRUARY 2006

1. SCOPE

This specification covers copper tubing in nominal sizes of 3/4", 1", 1-1/2" and 2".

2. GENERAL REQUIREMENTS

- a. Copper tubing shall be of the type commercially known as type "K" soft and conforms to NSF Standard 61, ASTM Specifications B-88, or latest revision thereof.
- b. 3/4" and 1" copper tubing shall be furnished in sixty-foot coils or one hundred-foot coil as specified; 1-1/2" shall be furnished in twenty-foot lengths, forty-foot coils or sixty-foot coils as specified, and 2" shall be furnished in twenty-foot lengths or forty foot coils as specified.