

100-20

**SAN ANTONIO WATER SYSTEM
SAN ANTONIO, TEXAS**

**SPECIFICATIONS FOR LIQUID CHLORINE
REVISED March 28, 2007**

1. **SCOPE**

This specification covers liquid chlorine.

2. **GENERAL REQUIREMENTS**

- a. Liquid chlorine shall conform to AWWA Specification B301-04, or latest revision thereof.
- b. Liquid chlorine shall be furnished in 150 pound or 2,000 pound containers, as specified.

Previous Specification Date
October 1992